

9.3 PROJECTED CONTRIBUTORY POPULATION AND PLANT CAPACITY

The current residential and commercial pillow counts are summarized in Table 7 along with the pillow count for the approved future developments at Silver Star Mountain. The treatment plant capacity is determined from these pillow counts as represented in Table 6 below.

Table 5: Pillow count and plant capacity.

	Pillow Count	Flow (cubic meters/day)
Existing Residential	5,888	1,111
Existing Commercial	3,203	604
Planned Future Development	8,682	1,638
TOTAL	17,773	3,353